

Work Order Status Change to RESPONDED

External



Maintenance Connection Agent - DO NOT REPLY <noreply@main... Thu, Oct 2, 2025, 5:50 AM



to me ▾

This email has been sent to notify you that Work Order #**218617** has been RESPONDED TO by the assigned Facilities Maintenance technician:

Location/Item: [REDACTED] - Dorm Room

Original Request: Want to check for **mold** in air conditioning

Labor Report: 10/2/2025 - [REDACTED] The AC unit vent cap was dirty.
I removed it, took it to the workshop, cleaned it, and reinstalled it back in place.

THIS IS AN AUTOMATED SYSTEM MESSAGE. If you have any questions, please contact [Work Management Center](#) or call (202)-687-3432.



GEORGETOWN UNIVERSITY
Planning & Facilities Management